

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/15/2012  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155631</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>11/07/2012</b>	
NAME OF PROVIDER OR SUPPLIER  <b>WHITE RIVER LODGE</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>3710 KENNY SIMPSON LN BEDFORD, IN 47421</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p><b>INITIAL COMMENTS</b></p> <p>A Life Safety Code Recertification, State Licensure and Quality Assurance Walk-thru Survey were conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 11/07/12</p> <p>Facility Number: 001153 Provider Number: 155631 AIM Number: 200155900</p> <p>Surveyor: Phillip Komsiski, Life Safety Code Specialist</p> <p>At this Life Safety Code survey, White River Lodge was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. This entire facility is surveyed since a two hour fire barrier does not separate the assisted living on 100 hall and the adjacent certified area. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors and hard wired smoke detectors in all resident sleeping rooms. The facility has a capacity of 113 and had a census of 50 at the time of this survey.</p> <p>The facility was found in compliance with state</p>			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/15/2012  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155631</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>11/07/2012</b>
NAME OF PROVIDER OR SUPPLIER  <b>WHITE RIVER LODGE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>3710 KENNY SIMPSON LN BEDFORD, IN 47421</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 1 law in regard to sprinkler coverage and smoke detector coverage.  All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered except for one garage which provides storage space for the facility and was not sprinklered.  Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 11/14/12.	K 000			